



POWERED AIRE INC.

www.poweredaire.com

**109 Mortensen Road
Greenville, PA 16125**

**Phone: 724-588-3305
Fax: 724-588-3371**

SUGGESTED AIRE CURTAIN SPECIFICATIONS MODEL BCE

All aire curtains furnished are complete factory assembled units as manufactured by Powered Aire Inc. Greenville, PA. Each unit consists of a stainless steel casing, centrifugal fans, raised stainless steel inlet screen, discharge nozzle, motor(s), and an optional 1/2 inch recleanable filter. The aire curtain unit provides a specific CFM and a uniform velocity across the entire length of the discharge area.

Units shall be furnished in single increments of sufficient structural strength to be supported from both ends without intermediate support. Multiple units shall not be permitted. Unit casing shall be a minimum of 18 gauge 304 stainless steel in a number three finish.

Motors at 1/2 H.P. 1400 rpm each shall be heavy duty type equipped with permanently lubricated, shielded ball bearings of equal size at each end and double extended shafts requiring no outboard bearings. Primary motor voltage shall be 115/208/230/480/575 volts 50/60 Hz single phase.

Galvanized fans shall be forward curved centrifugal type, double inlet design, with zinc plated hubs. Tangential type blowers and coupling connection shall not be permitted. Inlet screen shall be perforated stainless steel powder coated black.

Discharge nozzle shall be high efficiency discharge plenum, designed so that the air leaves on a 6 degree plane. Aire curtain creates a positive air seal with directional air foil vane. The vane shall facilitate deflection of air stream ± 20 degrees.

Consult factory for optional top air intake.

Complete Aire Curtain unit shall be ETL or UL listed, for the United States and Canada. When unit(s) will be mounted outdoors, unit(s) must bear ETL or UL label for outdoor use.

Unit shall be built to USDA and FDA compliance.

Unheated units shall have a 24 month warranty on all parts.

April, 2005